



Trace Analytical Laboratories, Inc.
2241 Black Creek Road
Muskegon, MI 49444-2673
Phone: 231.773.5998 Fax: 888.979.4467
www.trace-labs.com

State of Michigan Laboratory ID: 8001

March 15, 2017

Mr. Stephen King
Birmingham Public Schools
2305 Cole Street
Birmingham, MI 48009

PROJECT: Transportation

TRACE ID: T17B401-01

<i>Sample Point Description</i>	<i>Collected</i>		<i>Collected By</i>		<i>Received at Laboratory</i>	
T-03-BF	2/25/17	10:35	twb		2/27/17	9:07
Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.50 mg/L	1.3	3/13/17 7:27	3/14/17 16:45	dtm	EPA 200.8 Rev. 5.4
Lead	<0.0010 mg/L	0.015	3/13/17 7:27	3/14/17 16:45	dtm	EPA 200.8 Rev. 5.4

* The MCL (Maximum Contamination Limit) is the maximum concentration allowed under the Federal Safe Drinking Water Act. Results that are reported in bold or red have equaled or exceeded the MCL.

Jon Mink
Senior Project Manager



phone 231.773.5998
toll-free 800.733.5998
fax 231.773.6537

Trace Analytical Laboratories, Inc.
2241 Black Creek Road
Muskegon, MI 49444-2673
info@trace-labs.com
www.trace-labs.com

Birmingham Schools Fixture Inventory

Page 1 of 1

Building: **Transportation**

Date Collected: 2/25/17
Sampler's Initials: TWB

Trace ID: TT-713401
Logged by: JS
Checked by: EA

Trace No.	Time Taken	Sample Point	Location	Photo(s)	Aerator?	Connecting Plumbing	Notes
1	10:35	T-03-BF	Mechanic's Restroom	3679	Y	Br, Cu	

Released by: Tom Ben

Received by: [Signature]

Date: 2/27/17 Time: 9:07



the science of compliance

phone 231.773.5998
 toll-free 800.733.5998
 fax 231.773.6537

Trace Analytical Laboratories, Inc.
 2241 Black Creek Road
 Muskegon, MI 49444-2673
 info@trace-labs.com
 www.trace-labs.com

SAMPLE LOG IN CHECKLIST

Trace ID #: TM3401 Date: 2/27/17 Package Description: Cooler Temperature: 16.7
 Client Name: Birmingham Schools Time: 8:48 Logged in by: JS

Cooler Receipt

Cooler/samples delivered by: Trace courier
 Hand delivered Name of delivery person: Tom Brewer
 Commercial courier UPS FED EX US Mail
 Tracking Number: Not Applicable
 Tracking #: _____
 COC Seals present and intact on cooler? No Not Applicable
 Yes
 Custody seals signed by Client? No Client custody seal # (if applicable): _____
 Yes

Coolant and Temperature

Type of Coolant Used
 Slurry w/ crushed, cubed, or chip ice?
 Multiple bags of ice around samples?
 Ice Packs/ Blue Ice:
 No Coolant Present:
 Ice still present upon receipt (circle one):
 Yes No N/A

Cooler Temperature
 Correction Factors: • Digital Stick Thermometer CF = -1.0°C
 • Thermocouple CF = -1.0°C
 Temperature Blank: None °C (Digital Stick Thermometer)
 Range of 3 samples: 12.6-12.7 °C (Thermocouple)
 Melt Water: None °C (Use Digital Stick Thermometer)

General

	Yes	No	NA	Comments
All bottles arrived unbroken with labels in good condition?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Each sample point is in a sealed plastic bag?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Labels filled out completely?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
All bottle labels agree with Chain of Custody (COC)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Sufficient sample to run tests requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
pH checked and samples at correct pH?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	See Below*
Correct preservative added to samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Air bubbles absent from VOAs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
COC filled out properly and signed by client?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
COC signed in by TRACE sample custodian?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Was project manager called and samples discussed?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Notes:

***EMD pH Test Strips Used:**
 pH 0-2.5 Lot: HC563733 pH 11.0-13.0 Lot: HC547328
 Other: _____
 Lot: HC563733 verified 6/21/16 AY
 Lot: HC547328 verified 6/30/16 AY