

State of Michigan Laboratory ID: 8001

August 29, 2018

Mr. Stephen King
Birmingham Public Schools
2305 Cole Street
Birmingham, MI 48009


PROJECT: Seaholm Annex - Resample 082118

TRACE ID: T18H545-01

Sample Point Description *Collected* *Collected By* *Received at Laboratory*
AX-09-KF 8/21/18 5:30 twb 8/21/18 19:19

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.37 mg/L	1.3	8/27/18 12:39	8/28/18 11:06	jbb	EPA 200.8 Rev. 5.4
Lead	0.0034 mg/L	0.015	8/27/18 12:39	8/28/18 11:06	jbb	EPA 200.8 Rev. 5.4

* The MCL (Maximum Contamination Limit) is the maximum concentration allowed under the Federal Safe Drinking Water Act. Results that are reported in bold or red have equaled or exceeded the MCL.



Jon Mink
Senior Project Manager

Birmingham Schools Chain-of-Custody Record

Page 1 of 1

Building: **Seaholm Annex**

Date Collected 8-21-18

Trace ID: T18HS4S

Samplers Initials: TWB

Logged By: [Signature]

Checked By: [Signature]

Trace No.	Time Taken	Sample Point	Location	Photo(s)	Aerator?	Connecting Plumbing	Notes
1	5:30	AX-09-KF	Rm 7	2375	Y	Br, Cu	

Abbreviations:
 B= Classroom Bubbler
 BF= Bathroom Faucet
 Bottle= Bottle Filler
 CF= Classroom Faucet
 DF= Drinking Fountain
 DS= Deep Sink
 EW= Eye Wash
 HS= Hand Sink

Connecting Plumbing:
 Br= Brass
 Cu= Copper
 Pl= Plastic
 SS= Stainless Steel

Released by: [Signature] Received by: [Signature] Date: 8/21/18 Time: 19:19

SAMPLE LOG IN CHECKLIST

Trace ID #: T18H545 Date: 8/21/18 Package Description: Cooler Temperature: 21.6
 Client Name: Birmingham Schools Time: 19:19 Logged in by: dl

Cooler Receipt

Cooler/samples delivered by: Trace courier Hand delivered Commercial courier Name of delivery person: _____
 UPS FED EX US Mail

Tracking Number: Not Applicable Tracking #: _____
 COC Seals present and intact on cooler? Not Applicable No Yes
 Custody seals signed by Client? No Yes Client custody seal # (if applicable): _____

Coolant and Temperature

Type of Coolant Used
 Slurry w/ crushed, cubed, or chip ice?
 Multiple bags of ice around samples?
 Ice Packs/ Blue Ice:
 No Coolant Present:
 Ice still present upon receipt (circle one):
 Yes No N/A

Cooler Temperature
 Correction Factors: •Digital Stick Thermometer CF = -0.6°C
 •IR Thermometer CF = -0.8°C
 Representative Sample Temperature: 21.4 °C (check one below)
 Temp Blank (Stick Thermometer)
 Client Sample (IR Thermometer)
 Melt Water: N/A °C (Use Digital Stick Thermometer)

General

	Yes	No	NA	Comments
All bottles arrived unbroken with labels in good condition?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Each sample point is in a sealed plastic bag?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Labels filled out completely?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
All bottle labels agree with Chain of Custody (COC)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Sufficient sample to run tests requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
pH checked and samples at correct pH?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	See Below* pH will be verified at the time of the turbidity check.
Correct preservative added to samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Air bubbles absent from VOAs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
COC filled out properly and signed by client?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
COC signed in by TRACE sample custodian?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Was project manager called and samples discussed?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Notes:

***EMD pH Test Strips Used:**
 pH 0-2.5 Lot: HC731452 pH 11.0-13.0 Lot: HC600691
 Other: _____