

State of Michigan Laboratory ID: 8001

August 29, 2018

Mr. Stephen King
 Birmingham Public Schools
 2305 Cole Street
 Birmingham, MI 48009

PROJECT: Pierce

TRACE ID: T18H460-01

<i>Sample Point Description</i>	<i>Collected</i>	<i>Collected By</i>	<i>Received at Laboratory</i>
P-26-CF	8/16/18 5:45	twb	8/20/18 9:04

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.34 mg/L	1.3	8/27/18 12:39	8/28/18 10:04	jbb	EPA 200.8 Rev. 5.4
Lead	0.0042 mg/L	0.015	8/27/18 12:39	8/28/18 10:04	jbb	EPA 200.8 Rev. 5.4

TRACE ID: T18H460-02

<i>Sample Point Description</i>	<i>Collected</i>	<i>Collected By</i>	<i>Received at Laboratory</i>
P-30-CF	8/16/18 5:46	twb	8/20/18 9:04

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.18 mg/L	1.3	8/27/18 12:39	8/28/18 10:05	jbb	EPA 200.8 Rev. 5.4
Lead	0.0064 mg/L	0.015	8/27/18 12:39	8/28/18 10:05	jbb	EPA 200.8 Rev. 5.4

TRACE ID: T18H460-03

<i>Sample Point Description</i>	<i>Collected</i>	<i>Collected By</i>	<i>Received at Laboratory</i>
P-37-CF	8/16/18 5:47	twb	8/20/18 9:04

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.17 mg/L	1.3	8/27/18 12:39	8/28/18 10:07	jbb	EPA 200.8 Rev. 5.4
Lead	0.0063 mg/L	0.015	8/27/18 12:39	8/28/18 10:07	jbb	EPA 200.8 Rev. 5.4

* The MCL (Maximum Contamination Limit) is the maximum concentration allowed under the Federal Safe Drinking Water Act. Results that are reported in bold or red have equaled or exceeded the MCL.



Jon Mink
 Senior Project Manager

State of Michigan Laboratory ID: 8001

August 29, 2018

Mr. Stephen King
 Birmingham Public Schools
 2305 Cole Street
 Birmingham, MI 48009

PROJECT: Pierce

TRACE ID: T18H460-04

<i>Sample Point Description</i>	<i>Collected</i>	<i>Collected By</i>	<i>Received at Laboratory</i>
P-40-KF	8/16/18 5:48	twb	8/20/18 9:04

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	2.7 mg/L	1.3	8/27/18 12:39	8/28/18 12:32	jbb	EPA 200.8 Rev. 5.4
Lead	0.27 mg/L	0.015	8/27/18 12:39	8/28/18 12:13	jbb	EPA 200.8 Rev. 5.4

TRACE ID: T18H460-05

<i>Sample Point Description</i>	<i>Collected</i>	<i>Collected By</i>	<i>Received at Laboratory</i>
P-69-CF	8/16/18 5:49	twb	8/20/18 9:04


Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.15 mg/L	1.3	8/27/18 12:39	8/28/18 10:10	jbb	EPA 200.8 Rev. 5.4
Lead	<0.0010 mg/L	0.015	8/27/18 12:39	8/28/18 10:10	jbb	EPA 200.8 Rev. 5.4

TRACE ID: T18H460-06

<i>Sample Point Description</i>	<i>Collected</i>	<i>Collected By</i>	<i>Received at Laboratory</i>
P-88-DF	8/16/18 5:50	twb	8/20/18 9:04

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.26 mg/L	1.3	8/27/18 12:39	8/28/18 10:11	jbb	EPA 200.8 Rev. 5.4
Lead	<0.0010 mg/L	0.015	8/27/18 12:39	8/28/18 10:11	jbb	EPA 200.8 Rev. 5.4

* The MCL (Maximum Contamination Limit) is the maximum concentration allowed under the Federal Safe Drinking Water Act. Results that are reported in bold or red have equaled or exceeded the MCL.



Jon Mink
 Senior Project Manager

State of Michigan Laboratory ID: 8001

August 29, 2018

Mr. Stephen King
Birmingham Public Schools
2305 Cole Street
Birmingham, MI 48009

PROJECT: Pierce

TRACE ID: T18H460-07

<i>Sample Point Description</i>	<i>Collected</i>	<i>Collected By</i>	<i>Received at Laboratory</i>
P-90-CF	8/16/18 5:51	twb	8/20/18 9:04

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.38 mg/L	1.3	8/27/18 12:39	8/28/18 10:13	jbb	EPA 200.8 Rev. 5.4
Lead	0.051 mg/L	0.015	8/27/18 12:39	8/28/18 10:13	jbb	EPA 200.8 Rev. 5.4

* The MCL (Maximum Contamination Limit) is the maximum concentration allowed under the Federal Safe Drinking Water Act. Results that are reported in bold or red have equaled or exceeded the MCL.



Jon Mink
Senior Project Manager

Birmingham Schools Fixture Inventory

Page 1 of 1

Building: **Pierce**

Date Collected: 8-16-18
 Sampler's Initials: TAB

Trace ID: TR8H460
 Logged by: JS
 Checked by: [Signature]

Trace No.	Time Taken	Sample Point	Location	Photo(s)	Aerator?	Connecting Plumbing	Notes
1	5:45	P-26-CF	Rm 110	3490	Y	Br, Cu	
2	5:46	P-30-CF	Rm 109	3492	Y	Br, Cu	
3	5:47	P-37-CF	Rm 108	3497/98	N	Br, Cu	
4	5:48	P-40-KF	Media Workroom	3500/01	Y	Br, Cu	
5	5:49	P-69-CF	Rm 213	3523/24	Y	Br, Cu	
6	5:50	P-88-DF	Playground	3539	N	Unknown	
7	5:57	P-90-CF	Rm 106	3927/28/29	Y	Br, Cu	

Abbreviations: CF= Classroom Faucet, BF= Bathroom Faucet, HS= Handsink, EW= Eyewash, B= Classroom Bubbler
 Bottle= Bottle Filler, DF= Drinking Fountain
 Connecting Plumbing: Br=Brass, Cu= Copper, G= Galvanized, P=Plastic

Released by: [Signature]

Received by: [Signature]

Date: 8/20/18 Time: 09:04

SAMPLE LOG IN CHECKLIST

Trace ID #: <u>TR8H460</u>	Date: <u>8/20/18</u>	Package Description: <u>Coke</u>	Temperature: <u>21.0</u>
Client Name: <u>Birmingham</u>	Time: <u>9:04</u>	Logged in by: <u>JS</u>	

Cooler Receipt

Cooler/samples delivered by: Trace courier Hand delivered Commercial courier Name of delivery person: Tom Brewer

UPS FED EX US Mail

Tracking Number: Not Applicable
 Tracking #: _____

COC Seals present and intact on cooler? Not Applicable No Yes
 Custody seals signed by Client? No Yes Client custody seal # (if applicable): _____

Coolant and Temperature

<h5 style="text-align: center;">Type of Coolant Used</h5> <p>Slurry w/ crushed, cubed, or chip ice? <input type="checkbox"/></p> <p>Multiple bags of ice around samples? <input type="checkbox"/></p> <p>Ice Packs/ Blue Ice : <input type="checkbox"/></p> <p>No Coolant Present: <input checked="" type="checkbox"/></p> <p>Ice still present upon receipt (circle one): Yes No <u>N/A</u></p>	<h5 style="text-align: center;">Cooler Temperature</h5> <p>Correction Factors: •Digital Stick Thermometer CF = -0.6°C •IR Thermometer CF = -0.8°C</p> <p>Representative Sample Temperature: <u>20.3</u> °C (check one below)</p> <p><input type="checkbox"/> Temp Blank (Stick Thermometer) <input checked="" type="checkbox"/> Client Sample (IR Thermometer)</p> <p>Melt Water: <u>none</u> °C (Use Digital Stick Thermometer)</p>
---	--

General				Comments
	Yes	No	NA	
All bottles arrived unbroken with labels in good condition?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Each sample point is in a sealed plastic bag?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Labels filled out completely?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
All bottle labels agree with Chain of Custody (COC)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Sufficient sample to run tests requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
pH checked and samples at correct pH?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	See Below*
Correct preservative added to samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Air bubbles absent from VOAs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
COC filled out properly and signed by client?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
COC signed in by TRACE sample custodian?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Was project manager called and samples discussed?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Notes:

***EMD pH Test Strips Used:**

pH 0-2.5 pH 11.0-13.0
 Lot: HC731452 Lot: HC600691

Other: _____