



Trace Analytical Laboratories, Inc.
 2241 Black Creek Road
 Muskegon, MI 49444-2673
 Phone: 231.773.5998 Fax: 888.979.4467
 www.trace-labs.com

State of Michigan Laboratory ID: 8001

March 15, 2017

Mr. Stephen King
 Birmingham Public Schools
 2305 Cole Street
 Birmingham, MI 48009

PROJECT: Berkshire

TRACE ID: T17B400-01

Sample Point Description BK-103-CF *Collected* 2/25/17 8:13 *Collected By* twb *Received at Laboratory* 2/27/17 8:48

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.70 mg/L	1.3	3/13/17 7:27	3/14/17 16:26	dtm	EPA 200.8 Rev. 5.4
Lead	0.0016 mg/L	0.015	3/13/17 7:27	3/14/17 16:26	dtm	EPA 200.8 Rev. 5.4

TRACE ID: T17B400-02

Sample Point Description BK-107-CF *Collected* 2/25/17 8:14 *Collected By* twb *Received at Laboratory* 2/27/17 8:48

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.16 mg/L	1.3	3/13/17 7:27	3/14/17 16:31	dtm	EPA 200.8 Rev. 5.4
Lead	0.0017 mg/L	0.015	3/13/17 7:27	3/14/17 16:31	dtm	EPA 200.8 Rev. 5.4

TRACE ID: T17B400-03

Sample Point Description BK-111-CF *Collected* 2/25/17 8:15 *Collected By* twb *Received at Laboratory* 2/27/17 8:48

Metals, Total	RESULT	* MCL	PREPARED	ANALYZED	BY	METHOD
Copper	0.28 mg/L	1.3	3/13/17 7:27	3/14/17 16:34	dtm	EPA 200.8 Rev. 5.4
Lead	<0.0010 mg/L	0.015	3/13/17 7:27	3/14/17 16:34	dtm	EPA 200.8 Rev. 5.4

* The MCL (Maximum Contamination Limit) is the maximum concentration allowed under the Federal Safe Drinking Water Act. Results that are reported in bold or red have equaled or exceeded the MCL.


 Jon Mink
 Senior Project Manager



phone 231.773.5998
 toll-free 800.733.5998
 fax 231.773.6537

Trace Analytical Laboratories, Inc.
 2241 Black Creek Road
 Muskegon, MI 49444-2673
 info@trace-labs.com
 www.trace-labs.com

Birmingham Schools Fixture Inventory

Page 1 of 1

Building: Berkshire

Date Collected: 2/25/17
 Sampler's Initials: ZWP

Trace ID: TF104100
 Logged by: JS
 Checked by: CA

Trace No.	Time Taken	Sample Point	Location	Photo(s)	Aerator?	Connecting Plumbing	Notes
1	8:13	BK-103-CF	Rm 101-Front	2841	Y	Br, Cu	
2	8:14	BK-107-CF	Rm 102-Right Wall-Right	2847	Y	Br, Cu	
3	8:15	BK-111-CF	Rm 102-Left Wall-Left	2851	Y	Br, Cu	

Abbreviations:

- B= Classroom Bubbler
- BF= Bathroom Faucet
- Bottle= Bottle Filler
- CF= Classroom Faucet
- DF= Drinking Fountain
- DS= Deep Sink
- EW= Eye Wash
- HS= Hand Sink
- KF= Kitchen Faucet

Connecting Plumbing:

- Br= Brass
- Cu= Copper
- G= Galvanized
- P= Plastic
- SS= Stainless Steel

Released by: [Signature]

Received by: [Signature]

Date: 2/27/17 Time: 8:48

SAMPLE LOG IN CHECKLIST

Trace ID #: TM3400 Date: 2/27/17 Package Description: Cooler Temperature: 16.7
 Client Name: Birmingham Schools Time: 8:48 Logged in by: JS

Cooler Receipt

Cooler/samples delivered by: Trace courier Hand delivered Commercial courier
 Name of delivery person: Tom Brewer
 UPS FED EX US Mail

Tracking Number: Not Applicable
 Tracking #: _____

COC Seals present and intact on cooler? No Yes Not Applicable

Custody seals signed by Client? No Yes Client custody seal # (if applicable): _____

Coolant and Temperature

Type of Coolant Used
 Slurry w/ crushed, cubed, or chip ice?
 Multiple bags of ice around samples?
 Ice Packs/ Blue Ice:
 No Coolant Present:

Ice still present upon receipt (circle one):
 Yes No N/A

Cooler Temperature
 Correction Factors: • Digital Stick Thermometer CF = -1.0°C
 • Thermocouple CF = -1.0°C

Temperature Blank: None °C (Digital Stick Thermometer)
 Range of 3 samples: 12.6-12.7 °C (Thermocouple)
 Melt Water: None °C (Use Digital Stick Thermometer)

General

	Yes	No	NA	Comments
All bottles arrived unbroken with labels in good condition?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Each sample point is in a sealed plastic bag?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Labels filled out completely?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
All bottle labels agree with Chain of Custody (COC)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Sufficient sample to run tests requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
pH checked and samples at correct pH?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	See Below*
Correct preservative added to samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Air bubbles absent from VOAs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
COC filled out properly and signed by client?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
COC signed in by TRACE sample custodian?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Was project manager called and samples discussed?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Notes:

*EMD pH Test Strips Used:

pH 0-2.5 Lot: HC563733 pH 11.0-13.0 Lot: HC547328

Other: _____

Lot: HC563733 verified 8/21/16 AY
 Lot: HC547328 verified 8/30/16 AY

