



Lead and copper water testing 2016/17

FEBRUARY 15, 2017

Lead and copper standards

- ▶ Lead

- ▶ Michigan DEQ & U.S. EPA 15 ppb (0.015 mg/L)

- ▶ Copper

- ▶ Michigan DEQ & U.S. EPA 1300 ppb (1.3 mg/L)

- ▶ 1 ppb = 0.001 mg/L

- ▶ All sampling and testing procedures were performed in accordance with the MDEQ Guidance on drinking water sampling for lead and copper at schools and daycares on community water supplies (ver. 3.0, August 1, 2016)

Education / Administration Center

- ▶ 18 water sources tested
- ▶ 1 positive test results
- ▶ 0 positive results in *drinking specific* fixtures
- ▶ 0 positive results in foodservice kitchen area
- ▶ 0 positive results in large volume samples

G361-BF South men's bathroom (right)

Copper 1.3 mg/L
Lead N/A mg/L

Aerator changed

February 2017.

Re-test 2-25-17 passed

