



Lead and copper water testing 2016/17

JANUARY 17, 2017

Greenfield Elementary School

- ▶ 85 water sources tested
- ▶ 14 positive test results
- ▶ 0 positive results in *drinking specific* fixtures
- ▶ 0 positive results in foodservice kitchen area
- ▶ 0 positive results in large volume samples

G37-DS Custodial Area

Copper 1.7 mg/L
Lead N/A mg/L



Permanently signed as “Not Drinking Water” August 2017

G49-CF Room 100

Sink at back of room

Copper 1.3 mg/L

Lead 0.016 mg/L



Aerator changed

January 2017.

Re-test 1-28-17 passed

G54-CF Media Center Office

Copper 2.0 mg/L
Lead N/A mg/L



Aerator changed

January 2017.

Re-test 1-28-17 passed

G56-CF Preschool

SINK ONLY bubbler (fountain) tested negative

Copper 1.3 mg/L

Lead N/A mg/L



Faucet, Supply lines, & Valves replaced 3/2017. Retested 5-13-17 PASSED

G60-BF Staff bathroom (2nd floor north)

Copper 1.6 mg/L
Lead N/A mg/L

Aerator changed

January 2017.

Re-test 1-28-17 passed



G62-BF

2nd Floor girls bathroom

Bathroom sinks **Middle sink only**

Copper 8.1 mg/L

Lead 0.024 mg/L

Aerator changed

January 2017.

Re-test 1-28-17 passed



G64-BF G65-BF G66-BF 2nd Floor boys bathroom

Bathroom sinks **All Three**

Copper 1) 26 mg/L 2) 37 mg/L 3) 23 mg/L

Lead 1) 0.070 mg/L 2) 0.11 mg/L 3) 0.068 mg/L



Aerator changed

January 2017.

Re-test 1-28-17 passed

G72-BF Room 206

Copper 2.7 mg/L
Lead N/A mg/L

Aerator changed

January 2017.

Re-test 1-28-17 passed



G75-CF Room 207

SINK ONLY bubbler (fountain) tested negative

Copper 1.8 mg/L

Lead N/A mg/L

Aerator changed

January 2017.

Re-test 1-28-17 passed



G77-CF Room 208

SINK ONLY bubbler (fountain) tested negative

Copper 4.6 mg/L

Lead N/A mg/L



Faucet, Supply lines, & Valves replaced . Retested August 2017 PASSED

G79-CF Room 209

SINK ONLY bubbler (fountain) tested negative

Copper 3.2 mg/L

Lead N/A mg/L



Faucet, Supply lines, & Valves replaced 3/2017. Retested 5-13-17 PASSED

G85-DS Boiler room

Copper 2.5 mg/L
Lead 0.099 mg/L



Permanently signed as "Not Drinking Water" August 2017