



Lead and copper water testing 2016/17

JANUARY 5, 2017

Lead and copper standards

- ▶ Lead

- ▶ Michigan DEQ & U.S. EPA 15 ppb (0.015 mg/L)

- ▶ Copper

- ▶ Michigan DEQ & U.S. EPA 1300 ppb (1.3 mg/L)

- ▶ 1 ppb = 0.001 mg/L

- ▶ All sampling and testing procedures were performed in accordance with the MDEQ Guidance on drinking water sampling for lead and copper at schools and daycares on community water supplies (ver. 3.0, August 1, 2016)

Seaholm HS - Annex

- ▶ 17 water sources tested
- ▶ 0 positive test results